

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240647
Address: 3712 SW CLAYTON PL, LEES SUMMIT, MO 640823716 SW CLAYTON PL, LEES SUMMIT, MO
640823718 SW CLAYTON PL, LEES SUMMIT, MO 640823710 SW CLAYTON PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Tuesday, June 11, 2024

Corrective Action Required:

1	Miscellaneous Correction	- Interior garage portal tie down straps passed - Exterior sheeting of garage portal is not continuous to the upper top plate. Both top plates need to be nailed for a proper portal inspection for code - Interior anchor bolts were not ready for inspection
---	-----------------------------	---

Inspection was scheduled for a portal only.

Comments: