

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20226269
Address: 2206 NW KILLARNEY LN, LEES SUMMIT, MO 64081

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Robb Popp	Failed - Stop Work	Tuesday, June 11, 2024

Corrective Action Required
1 Misc

Provide engineered documentation for spread footing on west side
(24" wide w 3 bars and cross bar 4' oc)

***6/11/24

-FOOTING WAS FAILED ON 2/723 AND IS STILL MISSING
ENGINEERED REPORT. STOP WORK IS ISSUED UNTIL RESOLVED

Comments: