

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240903
Address: 1924 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Not Ready	Tuesday, June 11, 2024

Corrective Action Required:

1	Miscellaneous Correction	1924 SW Merryman. All rough <ul style="list-style-type: none">•Fire block the top of the chases in the garage•Renail interior which includes the garage WSP per code or per engineer's letter that needs to be uploaded•Two studs are missing in the front entry by the front door south side, plans call for a 3 stud pack
---	--------------------------	---

Walk your property before scheduling any more inspections.
NOT READY FOR INSPECTION

DO NOT INSULATE

Comments: