

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216099  
Address: 4728 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                | Inspector: | Outcome: | Date:                 |
|----------------------------|------------|----------|-----------------------|
| <b>Sidewalk Inspection</b> | Nick Scott | Partial  | Tuesday, May 14, 2024 |

Informational:

1 Misc

2-5-24 NS Site visited for pre-pour inspection and it appears that for a pre pour the sidewalk and driveway meet city standards. will come back after they pour.

5-13-24 NS I received a phone call about the erosion control and I will not be doing a final inspection until erosion control is fixed and cleaned up.

6-11-24 NS Site visited to do a final inspection Sidewalk and Driveway pass city standards and ADA. Sidewalk still needs to be cleaned.

**Comments:**