



**LEE'S SUMMIT**  
MISSOURI



---

**FIRE DEPARTMENT**

**Prevention Division**  
**(816)969-1300**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20240055	Date:	June 11, 2024
Project Title:	30HOP STREETS OF WEST PRYOR - SHELL BUILDING	Applicant:	
Location:	1020 NW PRYOR RD, LEES SUMMIT, MO 64081		TECH ELECTRONICS OF KANSAS
Type of Work:			8202 MARSHAL DR
Occupancy Group:	N/A		LENEXA, KS 66214
Description:	NEW MULTI TENANT SHELL BUILDING	Primary:	(785) 379-0300
Construction Type:	Type VB (Unprotected)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review**

**Reviewed By: Craig Hill**

**Rejected**

1. Plans do not show the code reference for the design of the system. Please provide the code reference used.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**