

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20232726  
Address: 2200 NE DOUGLAS ST, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Vacuum</b>	Devon Perry	Passed	Tuesday, June 11, 2024

Informational:	
1      Misc	6-11-24 DP. ESS fixed manholes that needed repaired and all Manholes have now passed a vacuum test. MH16-008 PASSED MH16-009 PASSED MH A4 PASSED

**Comments:**