

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231975
Address: 1550 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection	Bobby Richest	Partial	Thursday, June 06, 2024

Informational:

1	Misc	6-6-24 Contractor (Bair Excavation) started digging for water tap to connect on water main. Also contractor installed service line from location of meter pit to building.
		6-12-24 BR Contractor (Bair Excavation) has installed meter and meter pit. Service line was tested for leaks at the connection on the meter and tap connection on water main which it has pass no leaks.

Comments: