

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236602
Address: 2773 SW 11TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, June 12, 2024

Corrective Action Required:

1	Misc	- strap the other side of laundry wall LIB (currently LIB cut and on fur out wall) - No vertical runs of NM in plenum space at main level hall bathroom (corrected) - Nail off studs top third corner of master bedroom OK to insulate
---	------	---

Comments: