

ALL SAFE FIRE PROTECTION, LLC

Fire Suppression Submittal

FIRE SPRINKLER SHOP SUBMITTAL

Date: June 11, 2024

Project: John Knox Courtyard Bldg. E
515 NW Moore Street
Lee's Summit, MO. 64081

Architect: SFCS Architecture
1927 S. Tryon Street, Ste. 207
Charlotte, NC. 28203

Contractor: Straub Construction Co., Inc.
7775 Meadow View Dr.
Shawnee, KS 66227

Subcontractor: All Safe Fire Protection, LLC
6603 Royal Street. Bldg. D
Pleasant Valley, MO. 64068

SCOPE OF WORK

THE ENTIRE BUILDING WILL BE PROTECTED BY A NEW WET SPRINKLER SYSTEM THROUGHOUT.
THE BALCONIES WILL HAVE DRY TYPE SPRINKLERS SUPPLIED FROM THE WET SYSTEM.
THERE WILL BE A STANDPIPE SYSTEM THAT SUPPLIES HOSE VALVES IN EACH OF 2 STAIRS.
THERE WILL BE SPRINKLER CONTROL VALVES FOR EACH FLOOR CONNECTED TO THE STANDPIPE IN THE EAST STAIR (STAIR #2).
EACH FLOOR OF THE BUILDING WILL BE ON A SINGLE SPRINKLER ZONE, EXCEPT THE THIRD AND FOURTH FLOORS WILL BE SUPPLIED BY A SINGLE ZONE WITH THE VALVE ASSEMBLY AND MAIN LOCATED ON THE THIRD FLOOR.

GENERAL NOTES

THE SPRINKLER SYSTEM IS TO BE INSTALLED IN ACCORDANCE WITH NFPA 13R, 2016 EDITION.
ALL PIPE TO BE PLASTIC, CPVC, LISTED FOR USE IN FIRE SPRINKLER SYSTEMS.
ALL PIPE AND FITTINGS TO CONFORM WITH REQUIREMENTS OF NFPA 13.
VALVES ON CONNECTIONS TO WATER SUPPLIES, SECTIONAL CONTROL VALVES AND OTHER VALVES IN SUPPLY PIPES TO SPRINKLERS SHALL BE SUPERVISED OPEN BY AN APPROVED METHOD (BY OTHERS).
IT IS THE OWNERS RESPONSIBILITY TO PROVIDE ADEQUATE HEAT TO KEEP THE SPRINKLER SYSTEM FROM FREEZING.
ALL SECTIONS OF TRAPPED PIPING SHALL HAVE AUXILIARY DRAINS WHERE REQUIRED.
ALL ELECTRICAL WIRING OF ALARM BELLS, FLOW SWITCHES AND TAMPER SWITCHES (IF REQUIRED) TO BE DONE BY OTHERS.
THE SPRINKLER SYSTEM IS TO BE TESTED IN ACCORDANCE WITH THE LATEST APPLICABLE NFPA STANDARDS.
HANGERS TO BE SPACED TO MEET NFPA REQUIREMENTS.
SEISMIC BRACING IS NOT REQUIRED.

KEY NOTES

- [1] SPRINKLERS SHALL NOT BE REQUIRED IN BATHROOMS WHERE THE BATHROOM AREA DOES NOT EXCEED 55 S.F. (PER NFPA 13R: 6.6.2)
- [2] SPRINKLERS SHALL NOT BE REQUIRED IN CLOTHES CLOSETS, LINEN CLOSETS, AND PANTRIES WITHIN DWELLING UNITS THAT MEET ALL OF THE FOLLOWING CONDITIONS:
- THE AREA OF THE SPACE DOES NOT EXCEED 24 S.F.
 - THE WALLS AND CEILINGS ARE SURFACED WITH NONCOMBUSTIBLE OR LIMITED-COMBUSTIBLE MATERIALS AS DEFINED BY NFPA 220, STANDARD ON TYPES OF BUILDING CONSTRUCTION.

DESIGN CRITERIA

DWELLING UNITS:
PER NFPA 13R
SPRINKLERS SPACED PER MANUFACTURER'S LISTING
CALCULATE UP TO MAXIMUM 4 SPRINKLERS OPERATING IN A COMPARTMENT
AT PRESSURE AND FLOW PER MANUFACTURER'S LISTING OR
AT MINIMUM OF 0.05 GPM/S.F., WHICHEVER IS GREATER

CORRIDOR, STAIR:
PER NFPA 13R
SPRINKLERS SPACED PER MANUFACTURER'S LISTING
CALCULATE UP TO MAXIMUM 4 ADJACENT SPRINKLERS OPERATING
AT PRESSURE AND FLOW PER MANUFACTURER'S LISTING OR
AT MINIMUM OF 0.05 GPM/S.F., WHICHEVER IS GREATER

MECHANICAL, STORAGE:
PER NFPA13R: 7.2.3.1
PER NFPA 13, ORDINARY HAZARD GROUP 1
CALCULATE UP TO A MAXIMUM OF 4 SPRINKLERS IN A COMPARTMENT
AT 0.15 GPM/S.F.
MAXIMUM 150 S.F. PER SPRINKLER

ATRIUM:
PER NFPA 13, LIGHT HAZARD
0.10 GPM/S.F. FOR 1500 S.F.
(REDUCED OPERATING AREA FOR USE OF Q.R. SPRINKLERS AS APPLICABLE)
MAXIMUM 225 S.F. PER SPRINKLER
100 GPM HOSE ALLOWANCE
WATER CURTAIN TO BE CALCULATED AT 3 GPM PER LINEAR FOOT
PER NFPA 13: 11.3.3.1

STANDPIPE:
CLASS 1 STANDPIPE (WET MANUAL)
250 GPM AT 100 PSI AT TOP MOST OUTLET
PLUS 250 GPM FOR NEXT HIGHEST OUTLET
PLUS 250 GPM FOR EACH ADDITIONAL STANDPIPE
(TOTAL 750 GPM MAXIMUM FLOWING)
ASSUMED PRESSURE AT THE FDC IS 175 PSI


CONSTRUCTION

WOOD JOISTS AND TRUSSES.



FLOW TEST

FLOW TEST:
STATIC: 98 PSI
RESIDUAL: 52 PSI WITH 1875 GPM FLOWING
LOCATION: 515 NW MOORE STREET
STATIC/RESIDUAL HYDRANT:
ELEVATION: SAME AS FINISHED FLOOR
DATE: 05/02/24
INFORMATION FROM: LEE'S SUMMIT WATER



SPRINKLERS NOT REQUIRED IN CONCEALED SPACES AS FOLLOWS:
per NFPA 13R, 2013, section 6.6.6:
Sprinklers shall not be required in attics, penthouses equipment rooms, elevator machine rooms, concealed spaces dedicated exclusively to and containing only dwelling unit ventilation equipment, crawl spaces, floor/ceiling spaces, noncombustible elevator shafts where the elevator cars comply with ANSI A17.1 and other concealed spaces that are not used or intended for living purposes or storage and do not contain fuel-fired equipment.



SOUTH STANDPIPE
(STAIR #1)




NORTH STANDPIPE
(STAIR #2)



COORDINATE ALL TAMPER AND FLOW SWITCHES
WITH ALARM CONTRACTOR.

PROVIDE HYDRAULIC INFORMATION IMMEDIATELY
ON RISER FOR ALL NEW HYDRAULIC AREA.

SPRINKLER RISER



REVISIONS:		
#	DATE	DESCRIPTION



Fire Sprinkler Solutions, Inc.
1704 NE 82nd Terrace, Kansas City, MO 64118
phone: 816-260-4897 fax: 816-468-5653

ALL SAFE FIRE PROTECTION LLC
6603D Royal Street
Pleasant Valley, MO. 64068
P-816-492-7202 F-816-492-7310
info@allsafefirepro.com

**JOHN KNOX VILLAGE
COURTYARDS BUILDING E**
New Independent Living Building
Lee's Summit, MO


STA. OF MISSOURI
REGISTERED PROFESSIONAL ENGINEER
NUMBER
5-02851
EXPIRES
06/30/25

CONTRACT NO.
CONTRACT WITH Straub Construction
DRAWN BY: PCL
CHECKED BY: VC
PLOTTED FOR: APPROVAL
DOCUMENT DATE: 06-11-24
SHEET NUMBER: 1 OF 5



SPRINKLER LEGEND											
SYMBOL	SPRINKLER TYPE	SIN #	FINISH	TEMP.	THREAD	K-FACTOR	1ST FLR	2ND FLR	3RD FLR	4TH FLR	TOTAL
●	RELIABLE MODEL FTReq49 RESIDENTIAL RECESSED PENDENT	R3516	WHITE	155°	1/2"	4.9	131	131	121	4	387
●	RELIABLE MODEL RFC49 RESIDENTIAL CONCEALED PENDENT	RC649	WHITE	165°	1/2"	4.9	21	21	20	–	62
◀	RELIABLE MODEL FTReq44 RESIDENTIAL SIDEWALL	R3531	WHITE	155°	1/2"	4.4	–	–	6	160	166
◀	RELIABLE MODEL FTRF56 Q.R. RECESSED PENDENT	FTRF56	WHITE	155°	1/2"	5.6	13	13	33	1	60
⊗	RELIABLE MODEL FTRF56 Q.R. PENDENT (EXPOSED – BELOW CEILING)	FTRF56	WHITE	155°	1/2"	5.6	–	–	–	10	10
⊗	RELIABLE MODEL CG-46 CONCEALED PENDENT	FTRF56	WHITE	155°	1/2"	5.6	28	27	6	–	61
◀	RELIABLE MODEL F3QR56 Q.R. STANDARD SPRAY DRY HORIZONTAL SIDEWALL	F3QR56	CHROME	200°	1/2"	5.6	13	13	13	13	52
						TOTAL	206	205	199	188	799

[illegible]



REVISIONS:

#	DATE	DESCRIPTION

Fire Sprinkler Solutions, Inc.

1704 NE 82nd Terrace, Kansas City, MO 64118
phone: 816-260-4897 fax: 816-468-5633

ALL SAFE FIRE PROTECTION LLC

6603D Royal Street
Pleasant Valley, MO. 64068
P: 816-492-7202
F: 816-492-7310
info@allsafefirepro.com

JOHN KNOX VILLAGE
COURTYARDS BUILDING E

New Independent Living Building
Lee's Summit, MO

STATE OF MISSOURI
Professional Engineer
No. 0000000000

CONTRACT NO.

CONTRACT WITH
Straub Construction



DRAWN BY:
PCL

CHECKED BY:
VC

PLOTTED FOR:
APPROVAL

DOCUMENT DATE:
06-11-24

SHEET NUMBER:
3 OF 5



PIPE SIZE (NOMINAL, INCHES)	3/4"	1"	1-1/4"	1-1/2"	2"	2-1/2"	3"	4"	6"	8"
STEEL PIPE (EXCEPT THREADED LIGHTWALL)	N/A	12'-0"	12'-0"	15'-0"	15'-0"	15'-0"	15'-0"	15'-0"	15'-0"	15'-0"
STEEL PIPE (THREADED LIGHTWALL)	N/A	12'-0"	12'-0"	12'-0"	12'-0"	12'-0"	12'-0"	N/A	N/A	N/A
COPPER	8'-0"	8'-0"	10'-0"	10'-0"	12'-0"	12'-0"	12'-0"	15'-0"	15'-0"	15'-0"
CPVC	5'-6"	6'-0"	6'-6"	7'-0"	8'-0"	9'-0"	10'-0"	N/A	N/A	N/A


SYMBOLS LEGEND	
SYMBOL	DESCRIPTION
*	DENOTES HYDRAULICALLY CALCULATED SPRINKLER
	HYDRAULIC REFERENCE POINT
	CEILING HEIGHT
TOJ	TOP OF JOIST ELEVATION ABOVE FINISHED FLOOR
	CENTERLINE OF PIPE DOWN FROM CEILING OR ROOF
	CENTERLINE OF PIPE A.F.F.
 RN	RISER NIPPLE
 DN	PIPE DOWN
o	VERTICAL SUPPLY RISER
	SPRINKLER RISER
	APPROVED TYPE HANGER ON PIPE

SPRINKLER LEGEND											
SYMBOL	SPRINKLER TYPE	SIN #	FINISH	TEMP.	THREAD	K-FACTOR	1ST FLR	2ND FLR	3RD FLR	4TH FLR	TOTAL
●	RELIABLE MODEL F1Res49 RESIDENTIAL RECESSED PENDENT	R3516	WHITE	155°	1/2"	4.9	131	131	121	4	387
●	RELIABLE MODEL RFC49 RESIDENTIAL CONCEALED PENDENT	RC049	WHITE	165°	1/2"	4.9	21	21	20	-	62
◀	RELIABLE MODEL F1Res44 RESIDENTIAL SIDEWALL	R3531	WHITE	155°	1/2"	4.4	-	-	6	160	166
⊙	RELIABLE MODEL F1FR56 Q.R. RECESSED PENDENT	F1FR56	WHITE	155°	1/2"	5.6	13	13	33	1	60
⊙	RELIABLE MODEL F1FR56 Q.R. PENDENT (EXPOSED - BELOW CEILING)	F1FR56	WHITE	155°	1/2"	5.6	-	-	-	10	10
⊗	RELIABLE MODEL GG-46 CONCEALED PENDENT	F1FR56	WHITE	155°	1/2"	5.6	28	27	6	-	61
◀	RELIABLE MODEL F3QR56 Q.R. STANDARD SPRAY DRY HORIZONTAL SIDEWALL	F3QR56	CHROME	200°	1/2"	5.6	13	13	13	13	52
TOTAL							206	205	199	188	799

Fire Sprinkler Solutions, Inc.
1704 NE 82nd Terrace, Kansas City, MO 64118
phone: 816-260-4897 fax: 816-468-5633

 **ALL SAFE** FIRE PROTECTION LLC
6603D Royal Street
Pleasant Valley, MO. 64068
P: 816-492-7202
F: 816-492-7310
info@allsafefirepro.com


**JOHN KNOX VILLAGE
COURTYARDS BUILDING E**
New Independent Living Building
Lee's Summit, MO




CONTRACT NO.
CONTRACT WITH Straub Construction
DRAWN BY: PCL
CHECKED BY: VC
PLOTTED FOR: APPROVAL
DOCUMENT DATE: 06-11-24
SHEET NUMBER: 4 OF 5

Fire Sprinkler Solutions, Inc.
1704 NE 82nd Terrace, Kansas City, MO 64118
phone: 816-260-4897 fax: 816-468-5633

**JOHN KNOX VILLAGE
COURTYARDS BUILDING E**
New Independent Living Building
Lee's Summit, MO




Per NFPA 13, water curtain required at floor opening.
Draft stops are required per 8.15.4.2



THIRD FLOOR
ATRIUM
FIRE SPRINKLER PLAN

21'0" 4 8


SCALE 1/8"=1'-0"



FOURTH FLOOR
ATRIUM
FIRE SPRINKLER PLAN

2 10 4 8

SCALE 1/8"=1'-0"



SYMBOLS LEGEND	
SYMBOL	DESCRIPTION
*	DENOTES HYDRAULICALLY CALCULATED SPRINKLER
(I)	HYDRAULIC REFERENCE POINT
	CEILING HEIGHT
TOJ	TOP OF JOIST ELEVATION ABOVE FINISHED FLOOR
	CENTERLINE OF PIPE DOWN FROM CEILING OR ROOF
	CENTERLINE OF PIPE A.F.F.
○ RN	RISER NIPPLE
○ DN	PIPE DOWN
○	VERTICAL SUPPLY RISER
⬆	SPRINKLER RISER
—	APPROVED TYPE HANGER ON PIPE

SPRINKLER LEGEND											
SYMBOL	SPRINKLER TYPE	SIN #	FINISH	TEMP	THREAD	K-FACTOR	1ST FLR	2ND FLR	3RD FLR	4TH FLR	TOTAL
●	RELIABLE MODEL FTReq49 RESIDENTIAL RECESSED PENDENT	R3516	WHITE	155°	1/2"	4.9	131	131	121	4	387
●	RELIABLE MODEL RFC49 RESIDENTIAL CONCEALED PENDENT	RC649	WHITE	165°	1/2"	4.9	21	21	20	-	62
◀	RELIABLE MODEL FTReq44 RESIDENTIAL SIDEWALL	R3531	WHITE	155°	1/2"	4.4	-	-	6	160	166
◀	RELIABLE MODEL FTRF56 Q.R. RECESSED PENDENT	FTRF56	WHITE	155°	1/2"	5.6	13	13	33	1	60
⊗	RELIABLE MODEL FTRF56 Q.R. PENDENT (EXPOSED – BELOW CEILING)	FTRF56	WHITE	155°	1/2"	5.6	-	-	-	10	10
⊗	RELIABLE MODEL CG-46 CONCEALED PENDENT	FTRF56	WHITE	155°	1/2"	5.6	28	27	6	-	61
◀	RELIABLE MODEL F3QR56 Q.R. STANDARD SPRAY DRY HORIZONTAL SIDEWALL	F3QR56	CHROME	200°	1/2"	5.6	13	13	13	13	52
						TOTAL	206	205	199	188	799

Hydraulic Calculations

John Knox Village Courtyards Building E

New Independent Living Building


Lee's Summit, MO

Date: 06-11-24

Calculated by: Paul C. Link, P.E.

Area Summary:

Area	Description	GPM	PSI	Demand Location
Area #1	Fourth floor dwelling unit	168	61.2	at conn. to street main
Area #2	Third floor atrium	371	85.2	at conn. to street main
Area #3	Standpipe	750	152	at conn. to FDC



ALL SAFE FIRE PROTECTION LLC

6603D Royal Street
Pleasant Valley, MO. 64068
P:816-492-7202
F:816-492-7310
info@allsafefirepro.com

Fire Sprinkler Solutions, Inc.

1704 NE 82nd Terrace, Kansas City, MO 64118
phone: 816-260-4897 * fax: 816-468-5633

From: Ryan McCormick <Ryan.McCormick@cityofls.net>
Date: May 2, 2024 at 3:04:26 PM CDT
To: Vincent Corbin <vcorbin@allsafefirepro.com>
Subject: RE: 515 NW Moore St - Fire Hydrant Flow Data Request

Date: 5/2/24
Time: 2:20 pm

Static PSI: 98
Residual PSI: 52
Flow GPM: 1875

Yours Truly,

Ryan McCormick | Operations Technician
1200 SE Hamblen Road | Lee's Summit, MO 64081
816.969.1900 | lswater.net | Ryan.McCormick@cityofls.net

HYDRAULIC DESIGN INFORMATION SHEET

Name - John Knox Village Building E - Area #1 Date - 06-11-24
Location - 4th floor apartment
Building - John Knox Village Building E System No. - wet
Contractor - All Safe Fire Protection Contract No. -
Calculated By - Paul C. Link, P.E. Drawing No. -
Construction: (X) Combustible () Non-Combustible Ceiling Height 9'
OCCUPANCY - apartment

S Type of Calculation: () NFPA 13 Residential (X) NFPA 13R () NFPA 13D
Y Number of Sprinklers Flowing: () 1 () 2 (X) 4 ()
S () Other Calculate per listing
T () Specific Ruling Made by Date
E
M Listed Flow at Start Point - 16 Gpm System Type
Listed Pres. at Start Point - 13.3 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 20 () Deluge () PreAction
E Domestic Flow Added - N/A Gpm Sprinkler or Nozzle
S Additional Flow Added - 100 Gpm Make Reliable Model F1Res44
I Elevation at Highest Outlet - 42'8 Feet Size 1/2" K-Factor 4.4
G Note: calc 4 sprinklers in compartment Temperature Rating 155
N maximum spacing is 16' x 18'

Calculation Gpm Required 168 Psi Required 61.2 at base of riser
Summary C-Factor Used: Overhead 150 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 05-02-24 Rated Cap. Cap.
T Time of Test - @ Psi Elev.
E Static (Psi) - 98 Elev.
R Residual (Psi) - 52 Other Well
Flow (Gpm) - 1875 Proof Flow Gpm
S Elevation - 0
P Location: 515 NW Moore Street
P
L Source of Information: Lee's Summit Water
Y

Water Supply Curve C

Fire Sprinkler Solutions, Inc.
John Knox building E - Area #1


Page 2
Date 06-11-24

City Water Supply:

C1 - Static Pressure : 98
C2 - Residual Pressure: 52
C2 - Residual Flow : 1875

Demand:

D1 - Elevation : 18.480
D2 - System Flow : 67.945
D2 - System Pressure : 61.204
Hose (Demand) : 100
D3 - System Demand : 167.945
Safety Margin : 36.266



Fittings Used Summary

Fire Sprinkler Solutions, Inc.
John Knox building E - Area #1

Page 3
Date 06-11-24

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'El Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA 2007

Fire Sprinkler Solutions, Inc.
John Knox building E - Area #1

Page 4
Date 06-11-24

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TST	98.0	52	1875.0	97.47	167.94	61.204

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
101	42.67	4.4	13.23	16.0	
102	33.0		20.76		
103	33.0		21.44		
104	33.0		22.26		
105	33.0		22.87		
106	33.0		24.0		
107	33.0		27.83		
108	33.0		28.17		
FS3	29.67	4.4	42.79	100.0	
SP1	10.0		51.37		
1	10.0		51.74		
TOR	10.0		51.83		
BOR	0.0		61.18		
TST	0.0		61.2		
109	42.67		15.34		
110	33.0		23.68		
111	42.67	4.4	13.84	16.37	
112	33.0		22.24		
113	42.67		17.36		
114	33.0		26.74		

Final Calculations - Hazen-Williams - 2007

Fire Sprinkler Solutions, Inc.
John Knox building E - Area #1

Page 5
Date 06-11-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
101 to 102	42.67 33	4.40	16.00 16.0	0.75 0.874	2N 0.0	14.0 0.0	10.080 14.000	150 4.188			
						0.0	24.080	0.1387	3.340	Vel = 8.56	
102 to 103	33 33		0.0 16.0	1 1.101	N O	7.0 5.0	3.170 12.000	150 0.0	20.759 0.0		
						0.0	15.170	0.0451	0.684	Vel = 5.39	
103 to 104	33 33		0.0 16.0	1 1.101	N 0.0	7.0 0.0	11.170 7.000	150 0.0	21.443 0.0		
						0.0	18.170	0.0451	0.819	Vel = 5.39	
104 to 105	33 33		0.0 16.0	1 1.101		0.0 0.0	13.420 0.0	150 0.0	22.262 0.0		
						0.0	13.420	0.0450	0.604	Vel = 5.39	
105 to 106	33 33		16.38 32.38	1 1.101		0.0 0.0	6.830 0.0	150 0.0	22.866 0.0		
						0.0	6.830	0.1659	1.133	Vel = 10.91	
106 to 107	33 33		17.23 49.61	1 1.101	N 0.0	7.0 0.0	3.500 7.000	150 0.0	23.999 0.0		
						0.0	10.500	0.3653	3.836	Vel = 16.72	
107 to 108	33 33		0.0 49.61	2 2.003		0.0 0.0	16.750 0.0	150 0.0	27.835 0.0		
						0.0	16.750	0.0198	0.332	Vel = 5.05	
108 to FS3	33 29.67		18.34 67.95	2 2.003	6N 2O B S	66.0 20.0 7.779 14.261	263.750 108.039 371.789	150 1.442	28.167 1.442		
								0.0355	13.182	Vel = 6.92	
FS3 to SP1	29.67 10		0.0 67.95	4 4.26	T	26.334 0.0	19.750 26.334	120 8.519	42.791 8.519		
						0.0	46.084	0.0013	0.062	Vel = 1.53	
SP1 to 1	10 10		0.0 67.95	4 4.26	4E T	52.668 26.334	193.500 79.002	120 0.0	51.372 0.0		
						0.0	272.502	0.0014	0.371	Vel = 1.53	
1 to TOR	10 10		0.0 67.95	4 4.26	2E	26.334 0.0	39.080 26.334	120 0.0	51.743 0.0		
						0.0	65.414	0.0013	0.088	Vel = 1.53	
TOR to BOR	10 0		0.0 67.95	4 4.26		0.0 0.0	10.000 0.0	120 9.331	51.831 9.331	** Fixed Loss = 5	
						0.0	10.000	0.0014	0.014	Vel = 1.53	
BOR to TST	0 0		0.0 67.95	6 6.16	E T G	20.084 43.037 4.304	100.000 67.425 167.425	140 0.0	61.176 0.0		
								0.0002	0.028	Vel = 0.73	
TST			100.00 167.95						61.204	Qa = 100.00 K Factor = 21.47	
109 to 110	42.67 33	4.40	17.24 17.24	0.75 0.874	N O	7.0 3.0	16.080 10.000	150 4.188	15.344 4.188		
						0.0	26.080	0.1590	4.148	Vel = 9.22	
110 to 106	33 33		0.0 17.24	1 1.101	O	5.0 0.0	1.170 5.000	150 0.0	23.680 0.0		
						0.0	6.170	0.0517	0.319	Vel = 5.81	

Final Calculations - Hazen-Williams

Fire Sprinkler Solutions, Inc.
John Knox building E - Area #1

Page 6
Date 06-11-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
106			0.0 17.24					23.999		K Factor = 3.52	
111 to 112	42.67 33	4.40	16.37	0.75	2N 14.0	15.080 0.0	150	13.842 4.188			
112 to 105	33 33		16.37	0.874	0.0	29.080	0.1446	4.206		Vel = 8.75	
112 to 105	33 33		0.0	1	N O 7.0	1.420 12.000	150	22.236 0.0			
105			16.37	1.101	0.0	13.420	0.0469	0.630		Vel = 5.52	
105			0.0 16.37					22.866		K Factor = 3.42	
113 to 114	42.67 33	4.40	18.33	0.75	2N 14.0	15.080 0.0	150	17.364 4.188			
114 to 108	33 33		18.33	0.874	0.0	29.080	0.1783	5.186		Vel = 9.80	
114 to 108	33 33		0.0	1	N O 7.0	12.660 12.000	150	26.738 0.0			
108			18.33	1.101	0.0	24.660	0.0579	1.429		Vel = 6.18	
108			0.0 18.33					28.167		K Factor = 3.45	

Hydraulic Design Information Sheet

Name - John Knox Village building E - area #2 Date - 06-11-24
Location - third floor atrium
Building - John Knox Village building E System No. - wet
Contractor - All Safe Fire Protection Contract No. -
Calculated By - Paul C. Link, P.E. Drawing No. -
Construction: (X) Combustible () Non-Combustible Ceiling Height - varies
Occupancy - apartment

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. (X) 1 () 2 () 3 () Ex.Haz.
Y () NFPA 231 () NFPA 231C () Figure Curve
S Other reduced operating area for use of QR sprinklers
T Specific Ruling Made By Date

E
M Area of Sprinkler Operation - 900 System Type Sprinkler/Nozzle
Density - 0.10 (X) Wet Make Reliable
D Area Per Sprinkler - varies () Dry Model F1FR56
E Elevation at Highest Outlet - 33' () Deluge Size 1/2"
S Hose Allowance - Inside () Preaction K-Factor 5.6
I Rack Sprinkler Allowance - () Other Temp.Rat.155
G Hose Allowance - Outside - 100
N

Note water curtain calculated at 3 gpm per linear foot

Calculation Flow Required - 371 Press Required - 85.2 at conn to main
Summary C-Factor Used: 120 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 05-02-24 Cap. -
T Time of Test - Rated Cap.- Elev.-
E Static Press - 98 @ Press -
R Residual Press - 52 Elev. - Well
Flow - 1875 Proof Flow
S Elevation - 0

U
P Location - 515 NW Moore Street
P
L Source of Information - Lee's Summit Water
Y

C Commodity Class Location
O Storage Ht. Area Aisle W.
M Storage Method: Solid Piled % Palletized % Rack
M
S R () Single Row () Conven. Pallet () Auto. Storage () Encap.
T A () Double Row () Slave Pallet () Solid Shelf () Non
O C () Mult. Row () Open Shelf
R K Flue Spacing Clearance:Storage to Ceiling
A Longitudinal Transverse
G
E Horizontal Barriers Provided:

Water Supply Curve C

Fire Sprinkler Solutions, Inc.
John Knox building E - Area #2


Page 2
Date 06-11-24

City Water Supply:

C1 - Static Pressure : 98
C2 - Residual Pressure: 52
C2 - Residual Flow : 1875

Demand:

D1 - Elevation : 14.292
D2 - System Flow : 271.101
D2 - System Pressure : 85.225
Hose (Demand) : 100
D3 - System Demand : 371.101
Safety Margin : 10.478



Fittings Used Summary

Fire Sprinkler Solutions, Inc.
John Knox building E - Area #2

Page 3
Date 06-11-24

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90' Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA 2007

Fire Sprinkler Solutions, Inc.
John Knox building E - Area #2

Page 4
Date 06-11-24

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TST	98.0	52	1875.0	95.702	371.1	85.225

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
DP03	31.0	5.6	7.0	14.82	
EQ03	33.0		6.41		
DP01	32.0	5.6	10.34	18.01	
EQ01	33.0		9.97		
DP05	32.0	5.6	7.18	15.01	
EQ05	33.0		6.99		
DP04	32.0	5.6	7.18	15.01	
EQ04	33.0		6.79		
DP02	31.0	5.6	7.0	14.82	
EQ02	33.0		6.21		
201	33.0	5.76	6.79	15.01	K=K @ EQ04
202	33.0	5.68	7.53	15.58	K=K @ EQ05
203	33.0		9.16		
204	33.0		10.88		
205	33.0		10.98		
206	33.0		11.35		
207	33.0		13.76		
208	33.0		19.96		
FS3	29.67		60.09		
SP1	10.0		69.41		
1	10.0		74.2		
TOR	10.0		75.35		
BOR	0.0		84.86		
TST	0.0		85.22	100.0	
209	33.0	5.94	6.86	15.57	K=K @ EQ02
210	33.0	5.85	7.46	15.99	K=K @ EQ03
211	33.0	5.85	7.81	16.36	K=K @ EQ03
212	33.0		9.0		
213	33.0	5.76	9.85	18.08	K=K @ EQ04
214	33.0		11.16		
215	33.0		11.27		
216	33.0		12.0		
217	33.0		12.37		
218	33.0		12.94		
219	33.0	5.7	10.14	18.17	K=K @ EQ01
220	33.0		10.88		
221	33.0		10.91		
222	33.0	5.7	10.17	18.19	K=K @ EQ01
223	33.0	5.7	10.23	18.25	K=K @ EQ01
224	33.0	5.7	10.51	18.49	K=K @ EQ01
225	33.0	5.68	10.94	18.77	K=K @ EQ05
226	33.0	5.7	10.58	18.55	K=K @ EQ01

Flow Summary - NFPA 2007

Fire Sprinkler Solutions, Inc.
John Knox building E - Area #2

Page 5
Date 06-11-24

NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
227	33.0	5.7	11.54	19.38	K=K @ EQ01
228	33.0	5.7	12.07	19.82	K=K @ EQ01
229	33.0	5.76	18.67	24.89	K=K @ EQ04

Final Calculations - Hazen-Williams - 2007

Fire Sprinkler Solutions, Inc.
John Knox building E - Area #2

Page 6
Date 06-11-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
DP03 to EQ03	31 33	5.60	14.82 14.82	1 1.101	O 0.0 0.0	5.0 5.000 7.000	150 0.0390	7.000 -0.866 0.273		Vel = 4.99	
EQ03			0.0 14.82					6.407		K Factor = 5.85	
DP01 to EQ01	32 33	5.60	18.01 18.01	1 1.101	0.0 0.0 0.0	1.000 0.0 1.000	150 0.0560	10.343 -0.433 0.056		Vel = 6.07	
EQ01			0.0 18.01					9.966		K Factor = 5.70	
DP05 to EQ05	32 33	5.60	15.01 15.01	1 1.101	O 0.0 0.0	1.000 5.000 6.000	150 0.0400	7.184 -0.433 0.240		Vel = 5.06	
EQ05			0.0 15.01					6.991		K Factor = 5.68	
DP04 to EQ04	32 33	5.60	15.01 15.01	1 1.101	0.0 0.0 0.0	1.000 0.0 1.000	150 0.0400	7.184 -0.433 0.040		Vel = 5.06	
EQ04			0.0 15.01					6.791		K Factor = 5.76	
DP02 to EQ02	31 33	5.60	14.82 14.82	1 1.101	0.0 0.0 0.0	2.000 0.0 2.000	150 0.0390	7.000 -0.866 0.078		Vel = 4.99	
EQ02			0.0 14.82					6.212		K Factor = 5.95	
201 to 202	33 33	5.76	15.01 15.01	1 1.101	N 0.0 0.0	7.0 11.500 7.000 18.500	150 0.0400	6.791 0.0 0.740		K = K @ EQ04 Vel = 5.06	
202 to 203	33 33	5.68	15.58 30.59	1 1.101	O 0.0 0.0	5.0 5.920 5.000 10.920	150 0.1494	7.531 0.0 1.631		K = K @ EQ05 Vel = 10.31	
203 to 204	33 33		47.92 78.51	2 2.003	N O 0.0	11.0 16.000 10.0 21.000 37.000	150 0.0463	9.162 0.0 1.714		Vel = 7.99	
204 to 205	33 33		-4.87 73.64	2 2.003	0.0 0.0 0.0	2.420 2.420	150 0.0413	10.876 0.0 0.100		Vel = 7.50	
205 to 206	33 33		18.25 91.89	2 2.003	0.0 0.0 0.0	6.000 6.000	150 0.0620	10.976 0.0 0.372		Vel = 9.36	
206 to 207	33 33		18.55 110.44	2 2.003	N O 0.0	11.0 6.700 10.0 21.000 27.700	150 0.0871	11.348 0.0 2.412		Vel = 11.24	
207 to 208	33 33		135.77 246.21	2 2.003	N 0.0 0.0	11.0 5.160 11.000 16.160	150 0.3838	13.760 0.0 6.202		Vel = 25.07	
208 to FS3	33 29.67		24.89 271.1	2 2.003	2N 2O B	22.0 20.0 7.779	20.300 64.039 84.339	150 0.4586	19.962 1.442 38.682	Vel = 27.60	

Final Calculations - Hazen-Williams

Fire Sprinkler Solutions, Inc.
John Knox building E - Area #2

Page 7
Date 06-11-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
					S	14.261					
FS3 to SP1	29.67 10		0.0 271.1	4 4.26	T	26.334 0.0 26.334 0.0	120 26.334 46.084	60.086 8.519 0.810			
							0.0176		Vel =	6.10	
SP1 to 1	10 10		0.0 271.1	4 4.26	4E T	52.668 26.334 0.0	193.500 79.002 272.502	120 69.415 0.0			
							0.0176		Vel =	6.10	
1 to TOR	10 10		0.0 271.1	4 4.26	2E	26.334 0.0 26.334 0.0	39.080 26.334 65.414	120 0.0			
							0.0176		Vel =	6.10	
TOR to BOR	10 0		0.0 271.1	4 4.26		0.0 10.000 0.0 0.0	120 75.351 0.0	75.351 9.331			
							0.0176		* * Fixed Loss = 5		
									Vel =	6.10	
BOR to TST	0 0		0.0 271.1	6 6.16	E T G	20.084 43.037 4.304	100.000 67.425 167.425	140 0.0			
							0.0022		Vel =	2.92	
			100.00 371.10						Qa =	100.00	
TST								85.225	K Factor =	40.20	
209 to 210	33 33	5.94	15.57	1 1.101	N	7.0 0.0 0.0	7.000 7.000 14.000	150 0.0	6.862 0.0	K = K @ EQ02	
							0.0428		Vel =	5.25	
210 to 211	33 33	5.85	15.99	1.25		0.0 0.0 0.0	7.000 0.0 7.000	150 0.0	7.461 0.0	K = K @ EQ03	
							0.0501		Vel =	6.63	
211 to 212	33 33	5.85	16.36	1.25	O	6.0 0.0 0.0	4.920 6.000 10.920	150 0.0	7.812 0.0	K = K @ EQ03	
							0.1086		Vel =	10.07	
212 to 203	33 33		0.0 47.92	2 2.003		0.0 0.0 0.0	8.830 0.0 8.830	150 0.0	8.998 0.0		
							0.0186		Vel =	4.88	
203			0.0 47.92						9.162	K Factor =	15.83
213 to 214	33 33	5.76	18.08	1 1.101	2N O	14.0 5.0 0.0	4.170 19.000 23.170	150 0.0	9.850 0.0	K = K @ EQ04	
							0.0565		Vel =	6.09	
214 to 215	33 33		41.23	2		0.0 0.0 0.0	4.170 0.0 4.170	150 0.0	11.158 0.0		
							0.0276		Vel =	6.04	
215 to 216	33 33		18.49	2	N	11.0 0.0 0.0	4.990 11.000 15.990	150 0.0	11.273 0.0		
							0.0455		Vel =	7.92	
216 to 217	33 33		18.77	2		0.0 0.0 0.0	5.470 0.0 5.470	150 0.0	12.001 0.0		
							0.0680		Vel =	9.83	
217 to 218	33 33		19.38	2		0.0 0.0 0.0	6.000 0.0 6.000	150 0.0	12.373 0.0		
							0.0952		Vel =	11.81	
218 to 207	33 33		19.82	2		0.0 0.0 0.0	6.390 0.0 6.390	150 0.0	12.944 0.0		
							0.1277		Vel =	13.82	

Final Calculations - Hazen-Williams

Fire Sprinkler Solutions, Inc.
John Knox building E - Area #2

Page 8
Date 06-11-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
207			0.0 135.77					13.760		K Factor = 36.60	
219 to 220	33 33	5.7	18.17	1	N O	7.0 5.0	1.000 12.000	150 0.0	10.141 0.0	K = K @ EQ01	
220 to 221	33 33		18.17	1.101		0.0	13.000	0.0570	0.741	Vel = 6.12	
220 to 221	33 33		4.87	2		0.0	6.000	150	10.882 0.0		
221 to 214	33 33		23.04	2.003		0.0	6.000	0.0047	0.028	Vel = 2.35	
221 to 214	33 33		18.19	2	N	11.0 0.0	6.580 11.000	150 0.0	10.910 0.0		
214			41.23	2.003		0.0	17.580	0.0141	0.248	Vel = 4.20	
214			0.0 41.23						11.158	K Factor = 12.34	
222 to 221	33 33	5.7	18.19	1	N O	7.0 5.0	1.000 12.000	150 0.0	10.168 0.0	K = K @ EQ01	
221			18.19	1.101		0.0	13.000	0.0571	0.742	Vel = 6.13	
221			0.0 18.19						10.910	K Factor = 5.51	
223 to 205	33 33	5.7	18.25	1	N O	7.0 5.0	1.000 12.000	150 0.0	10.229 0.0	K = K @ EQ01	
205			18.25	1.101		0.0	13.000	0.0575	0.747	Vel = 6.15	
205			0.0 18.25						10.976	K Factor = 5.51	
224 to 215	33 33	5.7	18.49	1	N O	7.0 5.0	1.000 12.000	150 0.0	10.508 0.0	K = K @ EQ01	
215			18.49	1.101		0.0	13.000	0.0588	0.765	Vel = 6.23	
215			0.0 18.49						11.273	K Factor = 5.51	
225 to 216	33 33	5.68	18.77	1	N O	7.0 5.0	5.590 12.000	150 0.0	10.936 0.0	K = K @ EQ05	
216			18.77	1.101		0.0	17.590	0.0605	1.065	Vel = 6.33	
216			0.0 18.77						12.001	K Factor = 5.42	
226 to 206	33 33	5.7	18.55	1	N O	7.0 5.0	1.000 12.000	150 0.0	10.578 0.0	K = K @ EQ01	
206			18.55	1.101		0.0	13.000	0.0592	0.770	Vel = 6.25	
206			0.0 18.55						11.348	K Factor = 5.51	
204 to 220	33 33		4.87	2	N	11.0 0.0	9.170 11.000	150 0.0	10.876 0.0		
220			4.87	2.003		0.0	20.170	0.0003	0.006	Vel = 0.50	
220			0.0 4.87						10.882	K Factor = 1.48	
227 to 217	33 33	5.7	19.38	1	N O	7.0 5.0	1.000 12.000	150 0.0	11.538 0.0	K = K @ EQ01	
217			19.38	1.101		0.0	13.000	0.0642	0.835	Vel = 6.53	
			0.0								

Final Calculations - Hazen-Williams

Fire Sprinkler Solutions, Inc.
John Knox building E - Area #2

Page 9
Date 06-11-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
217			19.38					12.373		K Factor = 5.51	
228 to 218	33 33	5.7	19.82	1	N O	7.0 5.0 12.000	150	12.074 0.0		K = K @ EQ01	
			19.82	1.101		0.0 13.000	0.0669	0.870		Vel = 6.68	
218			0.0 19.82					12.944		K Factor = 5.51	
229 to 208	33 33	5.76	24.89	1	N O	7.0 5.0 12.000	150	18.668 0.0		K = K @ EQ04	
			24.89	1.101		0.0 12.690	0.1020	1.294		Vel = 8.39	
208			0.0 24.89					19.962		K Factor = 5.57	

HYDRAULIC DESIGN INFORMATION SHEET

Name - John Knox building E - Standpipe - Area #5 Date - 06-11-24
Location - stair
Building - John Knox building E System No. - standpipe
Contractor - All Safe Fire Protection Contract No. -
Calculated By - Paul C. Link, P.E. Drawing No. -
Occupancy - apartments

S (X)NFPA 14 Number of Standpipes ()1 (X)2 ()3 ()4 ()
Y ()Other
S ()Specific Ruling Made by Date

T
E Flow at Top Most Outlet - 250 Gpm System Type
M Pres. at Top Most Outlet - 100 Psi (X) Wet () Dry
Flow For Ea. Additional Standpipe - 250 Gpm
D Total Additional Flow - 250 Gpm
E Elevation at Highest Outlet - 36.0 Feet
S Hose Valve Connection ()1 1/2" (X)2 1/2"
I Class Service (X)I ()II ()III
G Note:
N

Calculation Gpm Required 750 Psi Required 152 Fire Dept. Conn.
Summary C-Factor Used: Overhead 120 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - Cap.
T Time of Test - Rated Cap. Elev.
E Static (Psi) - 175 @ Psi
R Residual (Psi) - 175 Elev. Well
Flow (Gpm) - 750 Proof Flow Gpm
S Elevation - FDC

U
P Location: 175 psi at FDC

P
L Source of Information:
Y

Water Supply Curve C

Fire Sprinkler Solutions, Inc.
John Know building E - Standpipe area #3


Page 2
Date 06-11-24

City Water Supply:

C1 - Static Pressure : 175.1
C2 - Residual Pressure: 175
C2 - Residual Flow : 750

Demand:

D1 - Elevation : 14.509
D2 - System Flow : 750
D2 - System Pressure : 152.080
Hose (Demand) : _____
D3 - System Demand : 750
Safety Margin : 22.920



Fittings Used Summary

Fire Sprinkler Solutions, Inc.
John Know building E - Standpipe area #3

Page 3
Date 06-11-24

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA 2007

Fire Sprinkler Solutions, Inc.
John Know building E - Standpipe area #3

Page 4
Date 06-11-24

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
FDC	175.1	175	750.0	175.0	750.0	152.08

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
HOS	36.0	25	100.0	250.0	
H1	36.0		102.91		
H2	42.5		100.26	250.0	
SP1	10.0		116.58		
1	10.0		132.29	250.0	
TOR	10.0		139.83		
FDC	2.5		152.08		

Final Calculations - Hazen-Williams - 2007

Fire Sprinkler Solutions, Inc.
John Know building E - Standpipe area #3

Page 5
Date 06-11-24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
HOS to H1	36 36	25.00	250.00 250.0	2.5 2.469	T G	12.0 1.0 13.000 13.500	120 0.2154	100.000 0.0 2.908		Vel = 16.75	
H1 to H2	36 42.500		0.0 250.0	4 4.26		0.0 0.0 11.330 11.330	120 0.0151	102.908 -2.815 0.171		Vel = 5.63	
H2 to SP1	42.500+ 10	250.00	250.00 500.0	4 4.26	T	26.334 0.0 26.334 40.994	120 0.0545	100.264 14.076 2.235		Vel = 11.25	
SP1 to 1	10 10		0.0 500.0	4 4.26	4E T B	52.668 26.334 15.8 288.302	120 0.0545	116.575 0.0 15.717		Vel = 11.25	
1 to TOR	10 10	+ 250.00	250.00 750.0	4 4.26	2E	26.334 0.0 26.334 65.334	120 0.1154	132.292 0.0 7.541		Vel = 16.88	
TOR to FDC	10 2.500		0.0 750.0	4 4.26	E T S	13.167 26.334 28.968 77.969	120 0.1154	139.833 3.248 8.999		Vel = 16.88	
FDC			0.0 750.00					152.080		K Factor = 60.82	