

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20240118  
Address: 515 NW MOORE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Mandrel</b>	John Jackson	Partial	Wednesday, June 12, 2024

Informational:  
1 Misc 06/12/24 Wednesday JMJ (Sub Contractor SDI)  
Contractor mandrel 8" sanitary from MH-4 to MH-3, MH-3 to MH-2, and MH-2 to Existing MH-1.  
Mandrel test passed for all sanitary tested.

**Comments:**