

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20240118  
Address: 515 NW MOORE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Air Test</b>	John Jackson	Passed	Thursday, June 13, 2024

Informational:

1	Misc	06/12/24 Wednesday JMJ (Sub Contractor SDI) Air test passed from MH-4 to MH-3. Contractor plans to restart air test @ 7:30AM 06/13/24 Thursday.
		06/13/24 Thursday JMJ (Contractor Straub/Sub-Contractor SDI) Air test for 8" passed from MH-3 to MH-2, MH-2 to MH-1, MH-1 to Existing.

**Comments:**