

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234858
Address: 2147 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Alex Fischer	Failed	Thursday, June 13, 2024

Partial Correction:

1	Misc	-Missing grounding conductor to Ufer and gas line (Still missing ground to gas line) NOW JUST MISSING CLAMP TO GAS LINE
---	------	---

Comments: