



# Aquatic Facility Inspection Report

Jackson County Environmental Health  
3651 NE Ralph Powell Road Lee's Summit, MO 64064  
Phone 816-881-6690 Fax 816-881-1650

☐ Category 1 ☐ Category 2 ☐ Category 3  
☐ Seasonal ☐ Yearly

Facility Name Whispering Woods  
Address 2777 SW Pryor Rd  
Lee's Summit

Phone Number \_\_\_\_\_

Pool Manager \_\_\_\_\_

CPO Holder \_\_\_\_\_

Swimming Pool	<input checked="" type="checkbox"/>	Pre-Opening	<input type="checkbox"/>
Wading Pool	<input type="checkbox"/>	Routine	<input type="checkbox"/>
Spray Park	<input type="checkbox"/>	Re-inspection	<input checked="" type="checkbox"/>
Hot Tub	<input type="checkbox"/>	Complaint	<input type="checkbox"/>
Spa	<input type="checkbox"/>	Other	<input type="checkbox"/>

IN=In Compliance OUT=Out of Compliance N/A=Not Applicable N/O=Not Observed

Failure to comply with the regulations shall result in a re-inspection, revocation and/or delays in issuance of your operating permit.

Permit / Supervision	IN	OUT	N/A	N/O	Water	IN	OUT	N/A	N/O	Equipment / Equipment Room	IN	OUT	N/A	N/O
Permit posted					Chlorine (FAC) <u>3.5</u> (pool 1-10/spa 3-10/spray 2-10)	<input checked="" type="checkbox"/>				Accessible (clean/organized)				
Licensed operator reachable by phone within 30 minutes					Bromine _____ (pool 2-10, spa 4-10)					Automatic Disinfection Installed (working/filled/good repair)				
Licensed Operator valid license/posted					Ph <u>7.8</u> (7.2-7.8)	<input checked="" type="checkbox"/>				Filtration Maint (good repair)				
Qualified Lifeguards (number, chairs, certification)					Alkalinity <u>118</u> (60-180)					Chemical storage (off ground, out of sunlight.)				
Regulatory Authority Access					Spa-Water Temp (<104°F)					Ventilation (pool area & chemical room)				
Variance/Other _____					Spa (calcium hard. 150-250)					Flow Meter				
Restrooms / Shower Rooms					Clarity					Safety				
Shower facilities (Required for Cat. 1)					Cleanliness					General Safety				
Clean/Good Repair					Chemical Testing Equipment					Barrier Provided/Adequate				
Sanitary Supplies Provided					Other					Self-Close/Self-Latch Door or Gate				
Other					Signage					Ring Buoy w/Rope, Shepherds Crook.				
Documentation					Pool/Spa/Spray Ground Rules	<input checked="" type="checkbox"/>				Emergency Phone & Address	<input checked="" type="checkbox"/>			
Daily Chemical Readings					Max patron load posted					Underwater Lighting				
Chemicals used					Max patron load maintained					Depth Markers (deck & wall)				
Incidents (fecal/vomit/blood)					"No Smoking"					Point of Transition (5'+)				
Spa (super-chor/drain weekly)					"NO Diving" (signs as req.)					Ladders/Ramps/Stairs (Non-slip & handrails, maintained)				
Filtration Maintained (backwash/disposal)					No Lifeguard on Duty					Voluntary Closure Events				
Other					Signage @ entrance & throughout.					VGB Compliance (Main Drain)				
					Other					Skimmers				
										Spa Timer				
										Other				

## OBSERVATIONS/COMMENTS

- All items have been corrected. The Aquatic Venue is approved to operate

- First service will be Managing Pool -

☐ POOL OPERATOR NOT AVAILABLE - Report was left here:

☐ RE-INSPECTION: Scheduled for \_\_\_\_\_ due to deficiencies noted and/or history of repeat violations

☐ POOL CLOSED: Facilities closed by this office MAY NOT re-open until approval is given.

Inspected By \_\_\_\_\_

Received By \_\_\_\_\_

Date 6/13/24