CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225614

Address: 4101 NE PORT DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Electrical Service Inspection Khanh Nguyen Failed Thursday, June 13,

2024

Corrective Action Required:

1 Misc -Remove the enamel at supply-side service raceway connection to service

disconnect enclosure and tighten lock nut

-Provide main bonding jumper sized per 250.102 from the bus bar, where the grounding electrode conductors are connected to, to the bus bar where the

service grounded conductor is connected to. NEC 250.24(A)(4)

-Tape EGC with green tape

Comments: