

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231984
Address: 2062 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Partial	Monday, October 02, 2023

Informational:
1 Misc 10-2-23 DP. DW is formed, aggregate compacted. Told to keep ADA compliance across the approach, approved to pour.
5-22-24 RH. Driveway meets ADA specification.

Comments: