

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20240118
Address: 515 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Vacuum	John Jackson	Partial	Thursday, June 13, 2024

Informational:
1 Misc 06/12/24 Wednesday JMJ (Sub Contractor SDI)
Vacuum test for MH A-4 passed. Vacuum tested passed for MH A-3, A-2, & A-1.
Existing MH failed vacuum test, the existing MH is made from cinderblocks.
I will inform Brent Dye of Water Department of the results.

Comments: