

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225614
Address: 4101 NE PORT DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Partial	Friday, June 14, 2024

Corrective Action Required:

1	FIRST FLOOR	-Install blockings for restroom grab bars -Secure MC within 12" of boxes -Slope drain toward drain
---	-------------	--

Rated wall at future elevator-OK to apply 5/8" type X GB

Comments: