

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241190
Address: 2134 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Alex Fischer	Failed	Friday, June 14, 2024

Corrective Action Required:

1	Miscellaneous Correction	- Exterior East side of garage sheeting does not extend to the upper top plate - Exterior of garage sheeting must be fastened to both top plates - Exterior of North side CSPF is not fastened in any pattern
---	--------------------------	---

Corrective Action Required:

2	Misc	-Inspection denied no drawings on site
---	------	--

Comments: