

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230570
Address: 1950 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Partial	Friday, June 14, 2024

Informational:

1 Misc

Underground electrical OK:
-CT to MDP; generator to EDP
-Bldg to generator/chiller area

Light poles:
-Underground raceways to 6 NE LP; 6 NE LP piers OK
-UE to 2 west LP; 2 west LP piers OK

Comments: