

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231252
Address: 2126 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Shawn Hoffman	Failed	Friday, June 14, 2024

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	- MAINTAIN EROSION CONTROL UNTIL SOD IS DOWN.
---	---------------------------------------	---

Comments: