

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240196
Address: 1712 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Not Ready	Friday, June 14, 2024

Corrective Action Required:

1	Misc	House not ready for occupancy inspection. List is incomplete -Provide erosion control before any further inspections -Missing all cover plates at kitchen -Missing cover plates in living room -Missing spark rings at switches in kitchen -Missing deck landing -Missing hammer arrestors -Missing primary and secondary latch at sliding glass door
---	------	--

Comments: