

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20240055
Address: 1020 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|-----------------------|
| Underground Electrical Inspection - Commercial | Robb Popp | Partial | Friday, June 14, 2024 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | Underground electrical OK to cover: -Raceways to light pole piers -Secondary lines from building to transformer, from transformer to sectionalizer and to end of lot for future use -2 Sets of (2) conduits for comm lines from north side of building @ 50' north (partial) |
|---|------|---|

Comments: