

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240647
Address: 3712 SW CLAYTON PL, LEES SUMMIT, MO 640823716 SW CLAYTON PL, LEES SUMMIT, MO
640823718 SW CLAYTON PL, LEES SUMMIT, MO 640823710 SW CLAYTON PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Monday, June 17, 2024

Corrective Action Required:

2	Miscellaneous Correction	Interior straps on all units passed
		3718 South exterior sheeting needs to be nailed to both top plates
		3716 Anchor bolts are not installed
		3712 Passed
		3710 Exterior sheeting needs to be nailed to both top plates Tightened down North side anchor bolt

Comments: