

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20241344
Address: 840 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Partial	Monday, June 17, 2024

Partial Correction:

1	Misc	Rooms 102-108, 117-131, 134-140 **Secure mc within 12" of boxes -Demo conductors at back wall fur out wall OK TO 1 side all locations
---	------	--

Comments: