

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20236555
Address: 1020 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Hydrostatic Test	Devon Perry	Passed	Tuesday, June 18, 2024

Informational:
1 Misc 6-14-24 DP. Crew performed hydrostatic test on the 8" water extension and also the 6" fire line. The 8" was tested at 150 psi for 2 hours and the 6" was tested at 200 psi for 2 hours. Both passed.

Comments: