

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20236555
Address: 1020 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Fire Line Construction Inspection	Devon Perry	Passed	Tuesday, June 18, 2024

Informational:
1 Misc 4/8/2024 DP. Crew was onsite and installed the fireline into the foundation and out 2 sticks. 6" C900 pipe with tracer wire.

Comments: