

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20240055
Address: 1020 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Robb Popp	Partial	Tuesday, June 18, 2024

Corrective Action Required:

1	Misc	Underground electrical OK to cover: -Raceways to light pole piers -Secondary lines from building to transformer, from transformer to sectionalizer and to end of lot for future use -1 4" conduit from future transformer at SE to future transformer at NE of east lot -2 Sets of (2) conduits for comm lines from north side of building to west of lot data location
---	------	---

Comments: