

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236587
Address: 1404 NE ERNEST WAY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Khanh Nguyen	Failed	Tuesday, June 18, 2024

Corrective Action Required:

1	Misc	-Support piping to structural slab every 4 ft -Vent the NE bathroom per code. Move the 3" waste stack connection min 30" f ft own stream of bath group plumbing
---	------	--

****Provide verification of the corrections to the above deficiencies**

****Not related to the underslab plumbing inspection, but the basement structural slab inspection from the engineer must be submitted to the city**

Comments: