

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20235213  
Address: 2971 SE SHENANDOAH PKWY, Unit:G2, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Foundation Inspection - Commercial</b>	Khanh Nguyen	Passed	Tuesday, June 18, 2024

Informational:	
1 Misc	Grounding connection must be made to the footing rebar, not wet-set rebar
	Foundation stem wall-OK

**Comments:**