

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235211
Address: 2991 SE SHENANDOAH PKWY, Unit:G3, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Foundation Inspection - Commercial	Khanh Nguyen	Passed	Tuesday, June 18, 2024

Informational:
1 Misc Grounding connection must be made to the footing rebar, not wet-set rebar

Foundation stem wall-OK

Comments: