

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231252
Address: 2126 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Tuesday, June 18, 2024

Corrective Action Required:

2	Miscellaneous Correction	2126 SW Rutherford. Occupancy
		-Fire block all holes or penetrations in the garage sheet rock
		-Hot water tank needs a lock out installed at the electrical panel
		-Splash blocks need to be installed

Comments: