

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240900
Address: 4416 SW GRINDSTONE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Patrick Schonfeldt	Passed	Wednesday, June 19, 2024

Informational:

1	Misc	6-12-24 PS Driveway approach pre pour, forms in place, aggregate compacted, approved to pour
		6-19-24 PS Driveway approach meets LS specs

Comments: