

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20233582
Address: 3640 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------|--------------------|----------|--------------------------|
| Pavement-Proof Roll | Patrick Schonfeldt | Partial | Wednesday, June 19, 2024 |

Informational:

| | | |
|---|------|---|
| 1 | Misc | 5-31-24 PS Contractor performed proof roll of compacted subgrade prior to placement of geogrid and aggregate base at parking lot. Third party inspector was on site for test. There were couple of areas of concern but they have been addressed by contractor. |
| | | 6-5-24 PS Inspected proof roll for surface at parking lot, areas inspected approved for surface asphalt construction |
| | | 6-11-24 PS Inspected proof roll for surface at parking lot, this is same area inspected on 6-5. Rain over weekend required another proof roll. Areas inspected approved for surface construction |
| | | 6-19-24 PS Inspected proof roll of compacted subgrade prior to placement of geogrid/aggregate at approach and road that connects to parking lot. Areas inspected approved for geogrid/aggregate placement |

Comments: