

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240196
Address: 1712 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Wednesday, June 19, 2024

Corrective Action Required:

2	Miscellaneous Correction	1712 SW Hightown. Occupancy (2) -Remove detector dust covers in the primary bedroom and basement mechanical room -Provide spark rings for kitchen backsplash light switches -Fire block all openings in garage sheet rock -Sod, splash pads and sump pump extension are not installed -Seal front exterior lighting
---	--------------------------	--

Comments: