

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212857

Address: 3807 SW WALSH DR, LEES SUMMIT, MO 640823803 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Thursday, June 20, 2024

Corrective Action Required:

2	Miscellaneous Correction	3803 SW Walsh. Occupancy -Label non GFCI receptacles in garage -Fire block (seal) the bottom of the chase in the garage -Stair riser height in the garage are not to code -Stairs in garage need guards (spindles) installed . Stairs have a vertical height over 30 inches and four or more steps.
---	--------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: