

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240682
Address: 3224 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, June 20, 2024

Corrective Action Required:

1	Misc	-Fire block plumbing chase and HVAC chase to ceiling space -complete cspf in bed 1 -missing lib in greatroom -strap top plate at pantry -missing stud at shower/office wall -fireblock penetration at foyer to hvac chase -missing lib bed 4 -column in basement in correct size -secure Se cable within 12" of disconnect -truss lateral bracing throughout -complete gas line installation
---	------	--

Comments: