

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231105  
Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Robb Popp	Failed	Thursday, June 20, 2024

Corrective Action Required:

1	Misc	-Label service as 1 of 5 -Install 3/0 conductor at ground rods -Install second ground rod min 6' from 1st ground rod -Submitt updated details showing change from 1000 amp to 1200 service
---	------	---

**Comments:**