

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240902
Address: 1928 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Passed	Thursday, May 30, 2024

Corrective Action Required:

1	Miscellaneous Correction	-Fasten interior CS-WSP according to engineers letter -Install triple windows in great room and bedroom 1 according to plan -Replace broken header at triple window in great room
---	--------------------------	---

Comments: