

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242971
Address: 4200 NE SUWANNEE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Khanh Nguyen	Failed	Friday, June 21, 2024

Corrective Action Required:

1	Misc	-Provide min 36" bottom stair landing depth, as measured in direction of travel
---	------	---------------------------------------------------------------------------------

Comments: