

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220490
Address: 2022 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Friday, June 21, 2024

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- pay all fees- Paint exterior gas piping- Label non GFCI outlets- Provide spark rings at kitchen counter outlets- Address stairs to basement, over 3/8" variance, some exceed 7 3/4" in rise- Provide security screws and latch at basement door- Label non GFCI outlet at sump- Sump discharge to be 36" from foundation- Seal top of A/C disconnect
---	------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: