

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240625
Address: 3722 SW CLAYTON PL, LEES SUMMIT, MO 640823726 SW CLAYTON PL, LEES SUMMIT, MO
640823728 SW CLAYTON PL, LEES SUMMIT, MO 640823730 SW CLAYTON PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Kyle Beard	Not Ready	Friday, June 21, 2024

Corrective Action Required:

2	Miscellaneous Correction	3730-3722 SW Clayton Rated assembly 3730 Passed 3728 vertical fire blocking is missing every 10 feet in living room/kitchen area Vertical fire block basement re room south wall every 10 feet on center (Unit 3728 was not ready for reinspection) 3726 vertical fire block living room utility room to bedroom 2 every 10 feet on center 3722 Passed Not a complete list for reinspection
---	-----------------------------	---

Comments: