

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240682  
Address: 3224 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Not Ready	Monday, June 24, 2024

Corrective Action Required:

1	Misc	-Fire block plumbing chase and HVAC chase to ceiling space -complete cspf in bed 1 -missing lib in greatroom -strap top plate at pantry -missing stud at shower/office wall -fireblock penetration at foyer to hvac chase -missing lib bed 4 -column in basement in correct size -secure Se cable within 12" of disconnect -truss lateral bracing throughout -complete gas line installation
---	------	--

Comments: