

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20235728
Address: 3726 SW MARYVILLE PL, LEES SUMMIT, MO 640823728 SW MARYVILLE PL, LEES SUMMIT, MO
640823730 SW MARYVILLE PL, LEES SUMMIT, MO 640823722 SW MARYVILLE PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Monday, June 24, 2024

Corrective Action Required:

2	Miscellaneous Correction	3722 SW Maryville. Occupancy
---	--------------------------	------------------------------

All units

-Seal all exterior penetrations

-Sod is not installed

-Splash pads not installed

-As graded plot plan is required before sodding

All units are on a TCO

TCO extension form was completed and excepted by the City

Comments: