



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110759, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Plumbing Inspection - Commercial	John Borns	Partial	Friday, September 16, 2011

Partial Correction
1 MISC

NO ISSUES FOUND ON C.I. PIPING AT: DWV ABOVE CEILING AT FRONT ENTRANCE CANOPY; VENTS FOR TWO FLOOR DRAINS @ PENTHOUSE FLOOR; DWV UNDER SECOND FLOOR PAN DECK;

Comments: