

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231814  
Address: 2201 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Engineering</b>	Nick Scott	Temporary C of O	Monday, June 24, 2024

Corrective Action Required:

1	Misc	6-24-24 NS site visited for a TCO which can be granted Punch list -Ground needs vegetation -fire hydrant 017-155 needs to be lowered to under 6 inches to grade -on the east side needs to have the two valves lowered to grade -both sides of where the water tie ins sidewalks need to be put back the east side needs 5 panels from what I see on google maps street view. west side needs one panel.
---	------	---

Comments: