



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PR20242738	Date:	June 24, 2024
Project Title:	JOHNSON LOGISTICS - JOHNSON STORAGE	Applicant:	
Location:	2225 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064	ADVANTAGE FIRE PROTECTION SYSTEMS INC	
		404 B NW 11TH ST	
		BLUE SPRINGS, MO 64015	
Type of Work:		Primary:	(816) 224-3400
Occupancy Group:	S-1		
Description:	JOHNSON STORAGE - OFFICE/RESIDENTIAL MOVING AND STORAGE		
Construction Type:	Type VB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. Before connecting this new area of the building a hydrostatic test will need to be performed at not less than 200 psi for 2 hours.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.