

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236601
Address: 3213 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, June 25, 2024

Corrective Action Required:

1	Misc	-Address to be properly illuminated -sod installed -splash blocks to extend 36" from foundation -water meter well to be brought to grade. Meter to be 14"-18" from top of meter to well lid ring -
---	------	--

Comments: