

devon.perry@cityofls.net

Report Email: devon.perry@cityofls.net

Copy Email:

Lab Report Fax No:

Lab Report Contact 1: (913) 915-2195

Lab Report Contact 2:

Customer ID No: 9297

Customer PO No:

Collected By: Client

Invoice No: 60752

Ricke Grading
 8200 Hedge Lane Terr.

Lenexa, KS 66227

Report of Analysis

Laboratory Report ID No:

20272

Project Name: STOWP Lot 13A

Item No.	Cat NO	ANALYSIS	COLLECTED	ANALYZED	REPORTING LIMIT	RESULTS
	Line NO	SAMPLE TYPE	SAMPLE SITE NOTES		TEST METHOD	
1	6191	Bacteria, P/A E. Coli	6/20/24	6/21/24	1 CFU/100mL	Negative CFU/100mL
	135214	Grab	8" Spot 1 Sample 3		SM9223 B	
2	6190	Bacteria, P/A T. Coliform	6/20/24	6/21/24	1 CFU/100mL	Negative CFU/100mL
	135213	Grab	8" Spot 1 Sample 3		SM9223 B	

Comments, if present, concern this Lab Work Order:

Sample did not change color but did fluoresce. This could indicate the presence of other kinds of bacteria such as Salmonella or Shigella.
 Strongly recommend rechlorinating the site!

The reported analytical results relate only to the sample submitted.

This report shall not be reproduced, except in full, without written approval by Blue Valley Laboratories, Inc.