

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20235233
Address: 1513 SW HEARTWOOD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Tuesday, June 25, 2024

Corrective Action Required:

1	Misc	-Missing trim under exterior deck sliding door -Seal exterior wall penetration at sump pump discharge and gas pipe -Open electrical box in basement electrical room (ceiling) -Missing sump pump extension pipe -Missing splash blocks -Missing sod
---	------	--

Comments: