

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232433
Address: 2122 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Dustin Agcopra	Partial	Tuesday, June 25, 2024

Corrective Action Required:

1	Misc	2-29-24 Dustin A, Broken Top hat for water valve and valve has debris in it. Will need to be corrected
---	------	--

Corrective Action Required:

2	Miscellaneous Correction	No erosion control measures are in place at the street and neighboring house on the east side. Full erosion control must be maintained until CofO
---	--------------------------	---

Corrective Action Required:

3	Misc	6-25-24 Dustin A. After reinspecting top hat , determined its not bad enough to replace. The dirt debris is still inside pipe and will need to be cleaned out so the valve can be accessible.
---	------	---

Comments: